

Hausadresse

IMA Materialforschung und Anwendungstechnik GmbH
Wilhelmine-Reichard-Ring 4 | 01109 Dresden | Germany

Postanschrift PF 80 01 44 | 01101 Dresden | Germany

Telefon +49(0)351 8837-0

Telefax +49(0)351 8837-6312

E-Mail ima@ima-dresden.de

Internet www.ima-dresden.de

Geschäftsführer

Prof. Dr.-Ing. Thomas Fleischer (Sprecher)
Thomas Reppe

Sitz der Gesellschaft: Dresden
Registergericht: Amtsgericht Dresden | HRB 5995
USt.-IdNr.: DE 155293995



Product Conformity

in accordance with

EN 488

is herewith confirmed

on basis of type tests according to EN 488:2015, Table 2 with reference to initial type test report
"V235/17.3"

for floating ball valves with full port and reduced port

Dimension range: DN 25 – DN 500

Construction: Ballomax and Ballomax DZT, material P235GH or equivalent

company

BROEN S.A.
Pieszyccka 10
58-200 Dzierżoniów

by

IMA Materialforschung und Anwendungstechnik GmbH

Wilhelmine-Reichard-Ring 4
01109 Dresden



Dresden, 05.02.2018

place, date

A handwritten signature in blue ink, appearing to read "Heiko Below".

Dipl. Ing. Heiko Below

Head of Department Pipe Systems

Recognised test laboratory of DVGW, DIN CERTCO and DIBt
The recognitions are valid for the test methods stated in the attachments of certificates of approval
DVGW LW-BU0023, DIN CERTCO PL121 and DIBt SAC 08